

City of Washington/East Washington Recreation Plan Washington Park Assessment					
Facility Name	Description	Condition	Age Groups Served	ADA Accessibility	Improvements (major/minor)
Pool Area - to be completed by pool subconsultant					
Lion's Club Pavilion					
Pavilion Shelter	42' x 60' picnic pavilion	Excellent	All	Yes	
Play Structure	Residential style wood structure	Fair	5 - 12 year olds	No	Not compliant to standards
Grill	Double size grill	Fair	Adults	Yes	
Water Fountain	Standard fountain	Fair	All	Yes	Needs painted
Trash Cans	55 gallon	Fair	All	Yes	Replace with receptacles/lids
Restrooms	Available in pavilion	See attachment			
Parking	Large parking lot located near entrance	Good	Adults	Yes	
Pavilion #1					
Pavilion Shelter	Under construction --adding kitchen and restrooms	Excellent	All	Yes	Fill along edges, cover drainage lines
Swings	3 bay swing set w/regular swings	Fair	All	No	Use zone not large enough
Grill	Regular grill	Fair	Adults	No	
Trash Cans	55 gallon	Fair	All	No	Replace with receptacle/lids
Restrooms	under construction	Excellent	All	Yes	
Parking	Stone parking area	Fair	Adults		Drainage issues
Kiwanis Pavilion/Pavilion #2					
Pavilion Shelter	40' x 75' pavilion	Good	All	Potentially	Widen walk & address slpoe to meet ADA requirements
Horse Shoe Pits	Two pits	Poor	Adults	No	Need renovated
Grill	Large charcoal grill	Fair	Adults	No	
Trash Cans	55 gallon	Fair	All	Yes	Replace with receptacles/lids
Restrooms	Available in pavilion	Good	All	Yes	
Parking	Stone parking w/asphalt pad	Fair	Adults	Yes	
Open Picnic Area Near Shelters #1 & 2					
Concrete pad - former pavilion	Concrete slab	Fair	All	No	Construct new pavilion on slab

<i>Picnic tables</i>	Four tables	Fair	All	No	
<i>Grills</i>		Poor	Adults	No	Grill top missing - remove post
<i>Trash Cans</i>					
<i>Open Space</i>	Scattered picnic tables & grills	Fair	All	No	Existing tree issues
<i>Parking</i>	Old road	Poor	Adults	No	Needs renovated
Stone Pavilion					
<i>Stone Pavilion</i>	64' x 56'	Fair	All	Yes	Reset raised stone in walking areas, remove staples from tables
<i>Play Structure</i>	Miracle Structure	Fair	5 - 12 year olds	Yes, but needs improvements	Improve ADA access,
<i>Grill</i>	Double size grill	Fair	Adults	Yes	
<i>Trash Cans</i>	55 gallon	Fair	All	Yes	Replace with receptacles/lids
<i>Restrooms</i>	Available in pavilion	Fair	All	Yes	Replace broken mirror
<i>Parking</i>	Paved parking area	Good	Adults	Yes	Replace Handicap Parking sign
Main Pavilion					
<i>2-story pavilion</i>	Large wooden structure	Poor -Fair	All	Yes, but needs improvements	Needs many cosmetic upgrades, improve ADA access, black mold issues
<i>Kitchen</i>	Large area	Good	Adults	Yes	Needs cosmetic upgrades, improve ADA access to stag
<i>Trash Cans</i>	55 gallon	Fair	All	Yes	Replace with receptacles/lids
<i>Restrooms</i>	Available in pavilion	Fair	All	Yes	Need improvements
<i>Parking</i>	Along road	Poor	Adults	Yes	Needs improved
Picnic Area/Playground Near Main Pavilion					
<i>Play Structure</i>	Small structure	Fair	2 -5 w/ 5 -12 features	No	Decrease dropoff heigth at end of slide
<i>Monkey Bars/Climber</i>	Arch & parallel bar climbers	Fair	5 - 12 year olds	No	
<i>Baby Swings</i>	Infant swing seate	Very Poor	Infants	No	Remove/Replace
<i>Swings (red seats)</i>					
<i>Swings (12')</i>	Four bay set	Poor to Fair	All	No	Remove/Replace
<i>Swings (10')</i>	Four Bay set w/regular seats	Poor to fair	All	No	Remove/Replace
<i>Picnic tables</i>	Scattered picnic tables	Fair	All	No	
<i>Grills</i>	Scattered single grills	Fair	Adults	No	

<i>Restrooms</i>	port-a-john nearby	Fair	All	No	
<i>Parking</i>	Along road	Poor	Adults	No	Need designated/immproved parking
<i>Open Space/Wooded Area</i>	Forest Management Issues --White Oak Tree with rotting base; --Fallen trees	Poor			Numerous Tree diseases and other issues
Bronco Fields					
<i>Main Field</i>	Baseball Field	Good	Youth	No	Replace bleachers, Fertilize & use herbicide, repair bare spots
<i>Practice Field</i>	Baseball Field	Good	Youth	No	Remove old pitch rubber, repair bare spots, 5 seat bleacher w/o rail
<i>Batting Cage</i>	Net cage	Poor	Youth	No	Needs improvements
Mustang Fields					
<i>Main Field</i>	Baseball Field	Fair	Youth	No	Drainage issues, matting floors - trip hazard, 5 seat bleachers w/o rails
<i>Practice Field</i>	Baseball Field	Fair	Youth	No	Drainage issues, erosion - trip hazard, 5 seat bleachers w/o rails
<i>Batting Cage</i>	Net cage	Good	Youth	No	
Pinto Field					
<i>Ball Field</i>	Baseball Field	Fair	Youth	No	Dugout roofs need repairs
<i>Shelter</i>	16'x 24' shelter	Good	All	No	
Shetland Field					
<i>Ball Field</i>	Baseball Field	Fair	Youth	No	6 seat bleacher w/o rail, need electric outlet cover at scoreboard
<i>Shelter</i>	20'x20' shelter	Good	All	No	
Colt Field					
<i>Ball Field</i>	Baseball Field	Fair	Youth	No	5 seat bleachers w/o rail - poor condition
<i>Concession/Announcer Booth</i>	Attached to dugouts	Fair	All	No	
Pony Field					
<i>Ball Field</i>	Baseball Field	Excellent	Youth	Yes	
<i>Concession Stands</i>	Two stands	Excellent	All	Yes	
T.W.I.S.T. Softball Fields					
<i>Field #1</i>	Softball Field	Fair	Youth	Yes	Weeds in fence line, remove 3 very poor condition bleachers

<i>Field #2</i>	Softball Field	Fair	Youth	Yes	Weeds in fence line, remove 2 poor condition bleachers
<i>Field #3</i>	Softball Field	Fair	Youth	No	Drainage issue on field
<i>Field #4</i>	Softball Field	Fair	Youth	No	Remove/Replace old bleacher
<i>Field #5</i>	Softball Field	Fair	Youth	No	Weeds in fence line, needs bleachers
<i>Field #6</i>	Softball Field	Fair	Youth	No	Drainage issues, remove old bleachers stored near parking area
Tennis Courts					
<i>Tennis Courts</i>	8 Courts	Good	All	No	Redo color coating, remove banking board, need new lights & better pole placement
Vernon C. Neal Sportsplex	Large indoor skating & deck hockey area	Excellent	Youth	Yes	
Historic Log Cabin					
<i>Cabin Structure</i>	Fort enclosed cabin	Fair	All	No	Overgrown with weeds
Hiking Trail	Natural trail	Good	All	No	Invasives need removed
Log House	Historic house	Fair	All	No	Boards on eaves need replaced, debris in back needs cleaned up, window missing
Park Roads		Poor - Fair	All		Drainage issues, Catch basins need repairs, road needs paved

