

7th WARD PLAYGROUND
ADDITIONAL OBSERVATIONS & COMMENTS

Walkways

- Concrete sidewalks around exterior of park
- Eight concrete steps into park
- Concrete ADA ramp into park with railings
- ADA curb cut from street near ADA parking space
- Concrete ADA ramp from upper to lower level of park
- ADA access to track impeded by two steps and then grass – replace with ramp
- Ten concrete steps with railing to lower level
- Concrete walk near steps has a significant drop off creating a potential hazard
- Sitting wall along lower level exterior walk – good condition

Light Standards not operable & falling apart at light fixtures

- Cover plate missing for wiring
- Conduit broken

Double bench

- Caps missing creating garbage collectors and bee nesting areas.

Pavilion

- Replace broken table
- Cover plate missing on electrical outlet

Asphalt areas

- Cracks need filled
- Debris needs cleaned up – weeds & leaf litter
- Potential drainage issue at bottom of bank near concrete play area

Landscaping

- Area between ramps needs cleared and re-landscaped
- Cut off shrubs along top of bank need removed – create a hazard

Swing sets

- First set has one infant and one regular seat – both be infant
 - Seats are in bad condition and need replaced
- Second set
 - One swing missing in each bay
 - Seats are in bad condition and need replaced

Teeter-totter

- Exposed concrete
- Seat missing
- Very loose

Spring animal

Exposed concrete

Lower play area

Plastic border has a section missing possibly to make it accessible

Merry Go Round

Works, but doesn't meet standards